



Notes:

1. Service line minimum depth of cover will be 36". Written permission will be required for coverage of less than 36".
2. Service line to be perpendicular to main sewer unless approved otherwise.
3. Services shall be located at points approved by the City. At each capped service line there shall be placed a service pole painted green. No services will be accepted unless they are reported by the contractor.
4. Service shall be constructed at 2% (1/4" per foot) minimum slope.
5. If a utility easement exists behind the Right-of-Way line, the service line shall be constructed across the easement. Otherwise, it shall be constructed to 1 foot behind the Right-of-Way line.
6. All excavation, sheeting, shoring, and bracing shall comply with all applicable OSHA standards.
7. Provide 3' of separation between lowest level served by gravity and crown of main sewer line at connection.